



Eastern Camden County Regional School District

Dr. Harold Melleby, Jr.
Interim Superintendent
hmelleby@eccrsd.us

Box 2500, Laurel Oak Road
Voorhees, NJ 08043
856-346-6740 FAX: 856-346-8388

May 13, 2025

Eastern Camden County Regional High School
1401 Laurel Oak Road
Voorhees, NJ 08043

Dear Eastern Camden County Regional School District Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Eastern Camden County Regional School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Eastern Regional will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

Testing Results

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within Eastern High School. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 102 samples taken, all but 1 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action Eastern Regional has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Result in µg/l (ppb)	Remedial Action
500 Cafeteria Kitchen Pot Filler ID# LW-025	18.9	Replaced Pot Filler- Flushed outlet- retested and collected results of 1.50

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing

greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at **www.eccrsd.us**. For more information about water quality in our schools, contact Donald A Hobbs, Sr at the Buildings and Grounds Department, 856-345-6755.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at **www.epa.gov/lead**, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

Harold Melleby, Jr.

Dr. Harold Melleby, Jr.
Interim Superintendent

HM/lsc

EASTERN REGIONAL HIGH SCHOOL
Initial and Confirmation Testing
Chain of Custody
Laboratory Results
Results - Excel



Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical

200 Route 130

Cinnaminson, NJ

01-00194

PHONE: (800) 220-3675

EMAIL: Cinnaminson.LeadLab@emsl.com

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

AD05572

Customer ID: COAS80		Billing ID:	
Company Name: Coastal Environmental Compliance LLC		Company Name: SAME	
Contact Name: Cathy Ledden		Billing Contact:	
Street Address: PO Box 167		Street Address:	
City, State, Zip: Hammonton, NJ 08037		City, State, Zip:	
Country:		Country:	
Phone: 609-820-9312		Phone:	
Email(s) for Report: coastalenvironmental@hotmail.com		Email(s) for Invoice:	

Project Name/No: Eastern Reg. High School - Lin Enfield		Purchase Order:	
EMSL LIMS Project ID: (If applicable, EMSL will provide)		US State where samples collected: NJ	
State of Connecticut (CT) must select project location:		Commercial (Taxable) <input type="checkbox"/> Residential (Non-Taxable) <input type="checkbox"/>	
Sampled By Name: Cathy Ledden		Sampled By Signature: <i>Cathy Ledden</i>	
No. of Samples in Shipment: 85		86	

Turn-Around-Time (TAT)

☐ 3 Hour ☐ 6 Hour ☐ 24 Hour ☐ 32 Hour ☐ 48 Hour ☐ 72 Hour ☐ 86 Hour ☐ 1 Week ☒ 2 Week

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS* <input type="checkbox"/> % by wt. <input type="checkbox"/> ppm (mg/kg) <input type="checkbox"/> mg/cm	SW 846-7000B	Flame Atomic Absorption	*Please select reporting limit on left.	
Chips reporting limit based on a minimum 0.25g sample weight. Not appropriate for Ceramic Tiles. XRF is recommended.	SW 846-6010D	ICP-OES	*Please select reporting limit on left.	
AIR	NIOSH 7082	Flame Atomic Absorption	4µg/filter	
	NIOSH 7303M	ICP-OES	1.0µg/filter	
	NIOSH 7303M	ICP-MS	0.05µg/filter	
WIPE <input type="checkbox"/> ASTM <input type="checkbox"/> NON-ASTM	SW 846-7000B	Flame Atomic Absorption	10µg/wipe	
If no box is checked, non-ASTM Wipe is assumed	SW 846-6010D	ICP-OES	1.0µg/wipe	
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)	
	22 CCR App. II, SW 846-6010D*	ICP-OES	2mg/kg (ppm)	
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	
Soil	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)	
	SW 846-6010D*	ICP-OES	2mg/kg (ppm)	
Wastewater	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	
Unpreserved				
Preserved with HNO3 <input type="checkbox"/> PH-2 <input type="checkbox"/>	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	
Drinking Water	EPA 200.6	ICP-OES	0.003 mg/L (ppm)	
Unpreserved <input checked="" type="checkbox"/>	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	
Preserved with HNO3 <input type="checkbox"/> PH-2 <input type="checkbox"/>				
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter	
Other:				

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
LW 300	300 Hall media - BF	X	12/21/24 730
LW 6ym	6ym Hall 1 - WF	X	731
LW 041	Gym 1 Boys Locker - WF		732
LW 042	Gym 1 Girls Locker - WF		733
LW 051	Gym 2 Boys Locker - WF		734

Method of Shipment: Hand		Sample Condition Upon Receipt:	
Relinquished by: <i>Cathy Ledden</i>	Date/Time: 12/21/24	Received by: <i>DB</i>	Date/Time: 12/21/24
Relinquished by:	Date/Time:	Received by: <i>Annex</i>	Date/Time: 12/23/24 0900

Control Document C0C-25 Lead R18 08/18/2024

*6010C Available Upon Request

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

01-00194
EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

AD05572

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

NEED Excel forms

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
LW 053	Gym 2 Girls Locker - WF		12/21/24 735
LW 053A	Gym 2 Girls Locker - WF		736
LW 026	600 Hallway - WF		737
LW 35	500 Hallway - BF		738
LW 050	500 Cafe - WF		739
LW 050A	500 Cafe - WF		740
LW 025	500 Kitchen Sink		741
LW 025A	500 Kitchen Sink		742
LW 025B	500 Kitchen Sink ^{cap} Pot filler		743
LW 029	Gym Hall 1 - BF		744
LW 029A	Gym Hall 1 - WF		745
LW 030	100 Hall - WF		746
LW 035	300 Hall - BF (Near media)		747
LW 035A	400 Hall - BF		748
LW 037	near Rm 303 - WF		749
LW 037A	400 Hall - BF		750
LW 038	Near Rm 314 - WF		751
LW 029	Near media - BF	✓	752
LW 039	Near 314 - WF	✓	753
LW 039A	Near 314 - WF	✓	754
LW 019	700 Hall - Near Rm 700 - WF	✓	755
LW 019A	700 Hall - Near Rm 700 - BF		756
LW 019B	700 Hall near Recital - WF ^{cap} Right Left		757
LW 019C	700 Hall near Recital - WF ^{cap} Right	✓	758
LW 018	near Rm 806 - WF		759
Method of Shipment:		Sample Condition Upon Receipt:	
Relinquished by:	Date/Time:	Received by: <i>[Signature]</i>	Date/Time: 12/23/24 0900
Relinquished by:	Date/Time:	Received by:	Date/Time:

Controlled Document CQC-25 Lead R19 08/10/2024

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference to their website. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

RECEIVED
EMSL
CINNAMINSON NJ



Lead Chain of Custody

EMSL Order Number / Lab Use Only

01-00194

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

EMSL ANALYTICAL, INC.
TESTING LABS - PRODUCTS - TRAINING

AD05572

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
23 LW 018A	Rm 806 - WF		12/21/24 800
LW 018B	Gym 2 - WF		801
24 LW 018C	Gym 2 - BF		802
25 LW 017D	Guidance - WF		803
26 LW 017C	Guidance - WF		804
27 LW 017	near Rm 15 - WF		805
28 LW 017A	near Rm 15 - WF		806
29 LW 014A	Foyer - WF main lobby		807
30 LW 014B	Foyer - WF main lobby		808
31 LW 012D	Red Hall - WF Left		809
32 LW 012A	Foyer - WF outside Red Hall		810
33 LW 012	Foyer - WF outside Red Hall		811
34 LW 013B	near Rm 60 - BF		812
35 LW 010A	90 Hall - BF		813
36 LW 010	90 Hall - BF WF		814
37 LW 09B	30 Hall Near Bathrooms - BF WF		815
38 LW 007	20 Cafe Hall - WF		816
39 LW 007A	20 Cafe Hall - BF		817
40 LW 003B	20 Cafe Hall - WF		818
41 LW 003C	20 Cafe Hall - WF		819
42 LW 004B	Rm 18 - WF Near Hall		820
LW 004C	Rm 18 - WF Hall Near		821
43 LW 031	near Rm 905 - WF		822
44 LW 031A	Wood Shop - Sink Area WF 906		823
45 LW 052	Trainers Rm - ICE MACHINE		824

Method of Shipment:

Sample Condition Upon Receipt:

Relinquished by:

Date/Time:

Received by:

Date/Time:

Relinquished by:

Date/Time:

Received by:

Date/Time:

Controlled Document CQC-25 Lead R19 08/19/2024



AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



01-00194

Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

AD05572

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
46 LW 054	Weight Rm - BF		12/21/24 825
47 LW 054A	Weight Rm - WF	60ml	826
47 LW 03	Rm 18 - Sink		827
48 LW 03A	Rm 18 - Sink		828
49 LW 06A	Cafe 20 Sink - 3 well RIGHT		829
50 LW 06B	Cafe 20 Sink - 2 well		830
51 LW 005	Cafe 20 Teachers - Sink		831
52 LW 005A	Cafe 20 Teachers - ICE MAKER		832
53 LW 005B	Cafe 20 Teachers - Sink - Filler		833
LW 049	Concession Ice Maker	Winterized	834
LW 049B	Concession Sink	Winterized	835
54 LW 049A	Sports Ice Maker	GO BACK AREA	836
55 LW 48	Culinary Arts - Sink		837
56 LW 48A	" " "		838
57 LW 48B	" " "		839
58 LW 48C	" " "		840
59 LW 48D	" " "		841
60 LW 48E	" " "		842
61 LW 48F	" " "		843
62 LW 48G	" " "		844
63 LW 48H	" " "		845
64 LW 48I	" " "		846
65 LW 48J	" " "		847
66 LW 48K	" " "		848
67 LW 48L	" " "		849

Method of Shipment:

Sample Condition Upon Receipt:

Relinquished by:

Date/Time:

Received by:

Date/Time:

Relinquished by:

Date/Time:

Received by:


Date/Time:

Controlled Document CQC-26 Lead R19 08/19/2024



AGREE TO ELECTRONIC SIGNATURE (By checking this box, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

EMSL Order Number / Lab Use Only

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

AD05572

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

[illegible]

Controlled Document COC-25 Lead R19 08/19/2024

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012505572**LIMS Reference ID:** AD05572**EMSL Customer ID:** COAS80**Attention:** Cathy Ledden

Coastal Environmental Compliance, LLC [COAS80]
PO Box 167

Hammonton, NJ 08037-0167

(609) 820-9312

coastalenvironmental@hotmail.com

Project Name:

01- 00194 / Eastern Reg. High School - Liw
Initial

Customer PO:**EMSL Sales Rep:**

Josh Silverman

Received:

12/23/2024 09:00

Reported:

01/22/2025 16:36

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LW 041/Gym 1 Boys Locker - WF									
Lims Reference ID:				AD05572-01		Matrix: Drinking Water		Sampled: 12/21/24 07:32:00	
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:31	01/02/25 17:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 042/Gym 1 Girls Locker - WF									
Lims Reference ID:				AD05572-02		Matrix: Drinking Water		Sampled: 12/21/24 07:33:00	
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:31	01/02/25 17:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 053/Gym 2 Girls Locker-WF									
Lims Reference ID:				AD05572-03		Matrix: Drinking Water		Sampled: 12/21/24 07:35:00	
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:31	01/02/25 17:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 053 A/Gym 2 Girls Locker-WF									
Lims Reference ID:				AD05572-04		Matrix: Drinking Water		Sampled: 12/21/24 07:36:00	
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:31	01/02/25 17:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 026/600 Hallway-WF									
Lims Reference ID:				AD05572-05		Matrix: Drinking Water		Sampled: 12/21/24 07:37:00	
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:31	01/02/25 17:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 35/500 Hallway-BF									
Lims Reference ID:				AD05572-06		Matrix: Drinking Water		Sampled: 12/21/24 07:38:00	
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:31	01/02/25 17:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 050/500 Cafe -WF									
Lims Reference ID:				AD05572-07		Matrix: Drinking Water		Sampled: 12/21/24 07:39:00	
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:31	01/02/25 17:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 050 A/500 Cafe -WF									
Lims Reference ID:				AD05572-08		Matrix: Drinking Water		Sampled: 12/21/24 07:40:00	
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:31	01/02/25 17:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 025/500 Kitchen Sink									
Lims Reference ID:				AD05572-09		Matrix: Drinking Water		Sampled: 12/21/24 07:41:00	
Metals									
Lead	1.10		1	1.00	µg/L	12/26/24 10:31	01/02/25 18:07	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax: 856-786-5974
 EMSL-CIN-01

EMSL Order ID: 012505572
LIMS Reference ID: AD05572
EMSL Customer ID: COAS80

Attention: Cathy Ledden

Coastal Environmental Compliance, LLC [COAS80]
 PO Box 167

Hammonton, NJ 08037-0167
 (609) 820-9312

coastalenvironmental@hotmail.com

Project Name:

01- 00194 / Eastern Reg. High School - Liw
 Initial

Customer PO:**EMSL Sales Rep:**

Josh Silverman

Received:

12/23/2024 09:00

Reported:

01/22/2025 16:36

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LW 025 A/500 Kitchen Sink Lims Reference ID: AD05572-10 Matrix: Drinking Water Sampled: 12/21/24 07:42:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:31	01/02/25 18:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 025 B/500 Kitchen Potfiller Lims Reference ID: AD05572-11 Matrix: Drinking Water Sampled: 12/21/24 07:43:00									
Metals									
Lead	18.9		1	1.00	µg/L	12/26/24 10:34	01/15/25 09:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 029/Gym Hall 1-BF Lims Reference ID: AD05572-12 Matrix: Drinking Water Sampled: 12/21/24 07:44:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 029 A/Gym Hall 1-WF Lims Reference ID: AD05572-13 Matrix: Drinking Water Sampled: 12/21/24 07:45:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 030/100 Hall 1-WF Lims Reference ID: AD05572-14 Matrix: Drinking Water Sampled: 12/21/24 07:46:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 035/300 Hall 1-BF (Near Media) Lims Reference ID: AD05572-15 Matrix: Drinking Water Sampled: 12/21/24 07:47:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 035 A/400 Hall 1-BF Lims Reference ID: AD05572-16 Matrix: Drinking Water Sampled: 12/21/24 07:48:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 037/Near Rm 303-WF Lims Reference ID: AD05572-17 Matrix: Drinking Water Sampled: 12/21/24 07:49:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 037 A/400 Hall-BF Lims Reference ID: AD05572-18 Matrix: Drinking Water Sampled: 12/21/24 07:50:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:15	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012505572
LIMS Reference ID: AD05572
EMSL Customer ID: COAS80

Attention: Cathy Ledden

Coastal Environmental Compliance, LLC [COAS80]
PO Box 167
Hammonton, NJ 08037-0167
(609) 820-9312
coastalenvironmental@hotmail.com

Project Name:

01- 00194 / Eastern Reg. High School - Liw
Initial

Customer PO:**EMSL Sales Rep:**

Josh Silverman

Received:

12/23/2024 09:00

Reported:

01/22/2025 16:36

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LW 038/Near Rm 3145-WF Lims Reference ID: AD05572-19 Matrix: Drinking Water Sampled: 12/21/24 07:51:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 019 A/700 Hall- Near Rm 700-BF Lims Reference ID: AD05572-20 Matrix: Drinking Water Sampled: 12/21/24 07:56:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 019 B/700 Hall- Near Recital-WF Left Lims Reference ID: AD05572-21 Matrix: Drinking Water Sampled: 12/21/24 07:57:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 018/Near Rm 806-WF Lims Reference ID: AD05572-22 Matrix: Drinking Water Sampled: 12/21/24 07:58:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 018 A/Rm 806-WF Lims Reference ID: AD05572-23 Matrix: Drinking Water Sampled: 12/21/24 08:00:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 018 C/Gym 2 - BF Lims Reference ID: AD05572-24 Matrix: Drinking Water Sampled: 12/21/24 08:02:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 017 D/Guidance- WF Lims Reference ID: AD05572-25 Matrix: Drinking Water Sampled: 12/21/24 08:03:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 017 C/Guidance- WF Lims Reference ID: AD05572-26 Matrix: Drinking Water Sampled: 12/21/24 08:04:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 017/Near Rm 15-WF Lims Reference ID: AD05572-27 Matrix: Drinking Water Sampled: 12/21/24 08:05:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:41	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012505572**LIMS Reference ID:** AD05572**EMSL Customer ID:** COAS80**Attention:** Cathy Ledden

Coastal Environmental Compliance, LLC [COAS80]
PO Box 167

Hammonton, NJ 08037-0167
(609) 820-9312

coastalenvironmental@hotmail.com

Project Name:

01- 00194 / Eastern Reg. High School - Liv
Initial

Customer PO:**EMSL Sales Rep:**

Josh Silverman

Received:

12/23/2024 09:00

Reported:

01/22/2025 16:36

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LW 017 A/Near Rm 15-WF Lims Reference ID: AD05572-28 Matrix: Drinking Water Sampled: 12/21/24 08:06:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 014 A/Foyer -WF Main Lobby Lims Reference ID: AD05572-29 Matrix: Drinking Water Sampled: 12/21/24 08:07:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 014 B/Foyer -WF Main Lobby Lims Reference ID: AD05572-30 Matrix: Drinking Water Sampled: 12/21/24 08:08:00									
Metals									
Lead	12.6		1	1.00	µg/L	12/26/24 10:34	01/15/25 10:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 012 D/Red Hall - WF Left Lims Reference ID: AD05572-31 Matrix: Drinking Water Sampled: 12/21/24 08:09:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 14:46	12/27/24 10:58	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: LW 012 A/Foyer-WF Outdie Red Hall Lims Reference ID: AD05572-32 Matrix: Drinking Water Sampled: 12/21/24 08:10:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 14:46	12/27/24 11:03	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: LW 012/Foyer-WF Outdie Red Hall Lims Reference ID: AD05572-33 Matrix: Drinking Water Sampled: 12/21/24 08:11:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 14:46	12/27/24 11:05	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: LW 013B/Near Rm 60-BF Lims Reference ID: AD05572-34 Matrix: Drinking Water Sampled: 12/21/24 08:12:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 14:46	12/27/24 11:07	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: LW 010 A/90 Hall -BF Lims Reference ID: AD05572-35 Matrix: Drinking Water Sampled: 12/21/24 08:13:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 14:46	12/27/24 11:09	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: LW 010/90 Hall -WF Lims Reference ID: AD05572-36 Matrix: Drinking Water Sampled: 12/21/24 08:14:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 14:46	12/27/24 11:15	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012505572**LIMS Reference ID:** AD05572**EMSL Customer ID:** COAS80**Attention:** Cathy Ledden

Coastal Environmental Compliance, LLC [COAS80]

PO Box 167

Hammonton, NJ 08037-0167

(609) 820-9312

coastalenvironmental@hotmail.com

Project Name:01- 00194 / Eastern Reg. High School - Liw
Initial**Customer PO:****EMSL Sales Rep:**

Josh Silverman

Received:

12/23/2024 09:00

Reported:

01/22/2025 16:36

Analytical Results**(Continued)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LW 09B/30 Hall Near Bathrooms- WF Lims Reference ID: AD05572-37 Matrix: Drinking Water Sampled: 12/21/24 08:15:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 14:46	12/27/24 11:17	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: LW 007/20 Cafe Hall-WF Lims Reference ID: AD05572-38 Matrix: Drinking Water Sampled: 12/21/24 08:16:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 14:46	12/27/24 11:19	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: LW 007 A/20 Cafe Hall-BF Lims Reference ID: AD05572-39 Matrix: Drinking Water Sampled: 12/21/24 08:17:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 14:46	12/27/24 11:21	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: LW 003 B/20 Cafe Hall-WF Lims Reference ID: AD05572-40 Matrix: Drinking Water Sampled: 12/21/24 08:18:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 14:46	12/27/24 11:23	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: LW 003 C/20 Cafe Hall-WF Lims Reference ID: AD05572-41 Matrix: Drinking Water Sampled: 12/21/24 08:19:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 004 B/Rm 18-WF Near Hall Lims Reference ID: AD05572-42 Matrix: Drinking Water Sampled: 12/21/24 08:20:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 031/Near Rm 905-WF Lims Reference ID: AD05572-43 Matrix: Drinking Water Sampled: 12/21/24 08:22:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 031 A/Wood Shop- WF 906 Lims Reference ID: AD05572-44 Matrix: Drinking Water Sampled: 12/21/24 08:23:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 052/Trainers Rm- ICE Machine Lims Reference ID: AD05572-45 Matrix: Drinking Water Sampled: 12/21/24 08:24:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:12	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012505572
LIMS Reference ID: AD05572
EMSL Customer ID: COAS80

Attention: Cathy Ledden

Coastal Environmental Compliance, LLC [COAS80]
PO Box 167
Hammonton, NJ 08037-0167
(609) 820-9312
coastalenvironmental@hotmail.com

Project Name:

01- 00194 / Eastern Reg. High School - Liw
Initial

Customer PO:**EMSL Sales Rep:**

Josh Silverman

Received:

12/23/2024 09:00

Reported:

01/22/2025 16:36

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LW 054/Weight Rm-BF Lims Reference ID: AD05572-46 Matrix: Drinking Water Sampled: 12/21/24 08:25:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 03/Rm 18-Sink Lims Reference ID: AD05572-47 Matrix: Drinking Water Sampled: 12/21/24 08:27:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 03 A/Rm 18-Sink Lims Reference ID: AD05572-48 Matrix: Drinking Water Sampled: 12/21/24 08:28:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 06 A/Cafe 20 Sink-3 Well Right Lims Reference ID: AD05572-49 Matrix: Drinking Water Sampled: 12/21/24 08:29:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 06 B/Cafe 20 Sink-2 Well Lims Reference ID: AD05572-50 Matrix: Drinking Water Sampled: 12/21/24 08:30:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 005/Cafe 20 Teachers - Sink Lims Reference ID: AD05572-51 Matrix: Drinking Water Sampled: 12/21/24 08:31:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 005 A/Cafe 20 Teachers - ICE Maker Lims Reference ID: AD05572-52 Matrix: Drinking Water Sampled: 12/21/24 08:32:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 005 B/Cafe 20 Teachers - Sink Filler Lims Reference ID: AD05572-53 Matrix: Drinking Water Sampled: 12/21/24 08:33:00									
Metals									
Lead	3.54		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 049 A/Sports Ice Maker Lims Reference ID: AD05572-54 Matrix: Drinking Water Sampled: 12/21/24 08:36:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:42	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012505572
LIMS Reference ID: AD05572
EMSL Customer ID: COAS80

Attention: Cathy Ledden

Coastal Environmental Compliance, LLC [COAS80]
PO Box 167
Hammonton, NJ 08037-0167
(609) 820-9312
coastalenvironmental@hotmail.com

Project Name:

01- 00194 / Eastern Reg. High School - Liw
Initial

Customer PO:**EMSL Sales Rep:**

Josh Silverman

Received:

12/23/2024 09:00

Reported:

01/22/2025 16:36

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LW 048/Culinary Arts - Sink Lims Reference ID: AD05572-55 Matrix: Drinking Water Sampled: 12/21/24 08:37:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 048 A/Culinary Arts - Sink Lims Reference ID: AD05572-56 Matrix: Drinking Water Sampled: 12/21/24 08:38:00									
Metals									
Lead	2.54		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 048 B/Culinary Arts - Sink Lims Reference ID: AD05572-57 Matrix: Drinking Water Sampled: 12/21/24 08:39:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 048 C/Culinary Arts - Sink Lims Reference ID: AD05572-58 Matrix: Drinking Water Sampled: 12/21/24 08:40:00									
Metals									
Lead	4.07		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 048 D/Culinary Arts - Sink Lims Reference ID: AD05572-59 Matrix: Drinking Water Sampled: 12/21/24 08:41:00									
Metals									
Lead	3.44		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 048 E/Culinary Arts - Sink Lims Reference ID: AD05572-60 Matrix: Drinking Water Sampled: 12/21/24 08:42:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 10:40	01/03/25 10:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 048 F/Culinary Arts - Sink Lims Reference ID: AD05572-61 Matrix: Drinking Water Sampled: 12/21/24 08:43:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 12:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 048 G/Culinary Arts - Sink Lims Reference ID: AD05572-62 Matrix: Drinking Water Sampled: 12/21/24 08:44:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 12:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 048 H/Culinary Arts - Sink Lims Reference ID: AD05572-63 Matrix: Drinking Water Sampled: 12/21/24 08:45:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 12:39	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012505572
LIMS Reference ID: AD05572
EMSL Customer ID: COAS80

Attention: Cathy Ledden

Coastal Environmental Compliance, LLC [COAS80]
PO Box 167
Hammononton, NJ 08037-0167
(609) 820-9312
coastalenvironmental@hotmail.com

Project Name:

01- 00194 / Eastern Reg. High School - Liw
Initial

Customer PO:**EMSL Sales Rep:**

Josh Silverman

Received:

12/23/2024 09:00

Reported:

01/22/2025 16:36

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LW 048 I/Culinary Arts - Sink Lims Reference ID: AD05572-64 Matrix: Drinking Water Sampled: 12/21/24 08:46:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 12:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 048 J/Culinary Arts - Sink Lims Reference ID: AD05572-65 Matrix: Drinking Water Sampled: 12/21/24 08:47:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 12:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 048 K/Culinary Arts - Sink Lims Reference ID: AD05572-66 Matrix: Drinking Water Sampled: 12/21/24 08:48:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 12:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 048 L/Culinary Arts - Sink Lims Reference ID: AD05572-67 Matrix: Drinking Water Sampled: 12/21/24 08:49:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 12:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 048 M/Culinary Arts - Sink Lims Reference ID: AD05572-68 Matrix: Drinking Water Sampled: 12/21/24 08:50:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 12:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 048 N/Culinary Arts - Sink Lims Reference ID: AD05572-69 Matrix: Drinking Water Sampled: 12/21/24 08:51:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 12:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 048 O/Culinary Arts - Sink Lims Reference ID: AD05572-70 Matrix: Drinking Water Sampled: 12/21/24 08:52:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 12:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 048 9/Culinary Arts - Sink Lims Reference ID: AD05572-71 Matrix: Drinking Water Sampled: 12/21/24 08:53:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 12:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 040/Maintenance Break Rm - Sink Lims Reference ID: AD05572-72 Matrix: Drinking Water Sampled: 12/21/24 08:54:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 13:04	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012505572**LIMS Reference ID:** AD05572**EMSL Customer ID:** COAS80**Attention:** Cathy Ledden

Coastal Environmental Compliance, LLC [COAS80]
PO Box 167

Hammonton, NJ 08037-0167
(609) 820-9312

coastalenvironmental@hotmail.com

Project Name:

01- 00194 / Eastern Reg. High School - Liw
Initial

Customer PO:**EMSL Sales Rep:**

Josh Silverman

Received:

12/23/2024 09:00

Reported:

01/22/2025 16:36

Analytical Results**(Continued)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LW 15A/Nurse Office -WF Lims Reference ID: AD05572-73 Matrix: Drinking Water Sampled: 12/21/24 08:55:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 13:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 15/Nurse Office - Sink Lims Reference ID: AD05572-74 Matrix: Drinking Water Sampled: 12/21/24 08:56:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 13:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 016A/Glass Hall Theatre - WF Lims Reference ID: AD05572-75 Matrix: Drinking Water Sampled: 12/21/24 08:57:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 13:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW 024/500 Teachers Lounge Sink Lims Reference ID: AD05572-76 Matrix: Drinking Water Sampled: 12/21/24 08:58:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 13:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: Blank Lims Reference ID: AD05572-77 Matrix: Drinking Water Sampled: 12/21/24 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 13:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW-0120 A/Red Hall WF- Right Lims Reference ID: AD05572-78 Matrix: Drinking Water Sampled: 12/21/24 08:59:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 13:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW-09 A/30 Hall Near Bathroom BF Lims Reference ID: AD05572-79 Matrix: Drinking Water Sampled: 12/21/24 09:00:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 13:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW-09 C/30 Hall Near Bathroom WF Lims Reference ID: AD05572-80 Matrix: Drinking Water Sampled: 12/21/24 09:01:00									
Metals									
Lead	ND		1	1.00	µg/L	12/26/24 13:07	01/03/25 13:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LW-09 D/30 Hall Near Bathroom WF Lims Reference ID: AD05572-81 Matrix: Drinking Water Sampled: 12/21/24 09:02:00									
Metals									
Lead	1.09		1	1.00	µg/L	12/26/24 14:46	12/27/24 11:25	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012505572
LIMS Reference ID: AD05572
EMSL Customer ID: COAS80

Attention: Cathy Ledden

Coastal Environmental Compliance, LLC [COAS80]
PO Box 167
Hammononton, NJ 08037-0167
(609) 820-9312
coastalenvironmental@hotmail.com

Project Name:

01- 00194 / Eastern Reg. High School - Liw
Initial

Customer PO:**EMSL Sales Rep:**

Josh Silverman

Received:

12/23/2024 09:00

Reported:

01/22/2025 16:36

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LW-006/Cafe 20 - 3 Well Left									
Lims Reference ID:			AD05572-82		Matrix: Drinking Water			Sampled: 12/21/24 09:03:00	
Metals									
Lead	ND	1	1.00	µg/L	12/26/24 14:46	12/27/24 11:31	JW1	EPA 200.8 (DA)/EPA 200.8	
Sample: LW-00A/Rm - 17 Sink Left									
Lims Reference ID:			AD05572-83		Matrix: Drinking Water			Sampled: 12/21/24 09:04:00	
Metals									
Lead	ND	1	1.00	µg/L	12/26/24 14:46	12/27/24 11:33	JW1	EPA 200.8 (DA)/EPA 200.8	
Sample: LW-00B/Rm - 17 Sink Right									
Lims Reference ID:			AD05572-84		Matrix: Drinking Water			Sampled: 12/21/24 09:05:00	
Metals									
Lead	ND	1	1.00	µg/L	12/26/24 14:46	12/27/24 11:39	JW1	EPA 200.8 (DA)/EPA 200.8	
Sample: LW-052A/Trainers Rm Sink									
Lims Reference ID:			AD05572-85		Matrix: Drinking Water			Sampled: 12/21/24 09:06:00	
Metals									
Lead	ND	1	1.00	µg/L	12/26/24 14:46	12/27/24 11:41	JW1	EPA 200.8 (DA)/EPA 200.8	
Sample: LW-907/Rm 907 Fountain									
Lims Reference ID:			AD05572-86		Matrix: Drinking Water			Sampled: 12/21/24 09:07:00	
Metals									
Lead	2.58	1	1.00	µg/L	12/26/24 14:46	12/27/24 11:43	JW1	EPA 200.8 (DA)/EPA 200.8	

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012505572
LIMS Reference ID: AD05572
EMSL Customer ID: COAS80

Attention: Cathy Ledden

Coastal Environmental Compliance, LLC [COAS80]
PO Box 167
Hammonton, NJ 08037-0167
(609) 820-9312
coastalenvironmental@hotmail.com

Project Name:

01- 00194 / Eastern Reg. High School - Liw
Initial

Customer PO:**EMSL Sales Rep:**

Josh Silverman

Received:

12/23/2024 09:00

Reported:

01/22/2025 16:36

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	68-00367	11/30/2025
NYSDOH	New York State Department of Health	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited	100194	01/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: 856-786-5974
EMSL-CIN-01

EMSL Order ID: 012505572**LIMS Reference ID:** AD05572**EMSL Customer ID:** COAS80**Attention:** Cathy Ledden

Coastal Environmental Compliance, LLC [COAS80]

PO Box 167

Hammonton, NJ 08037-0167

(609) 820-9312

coastalenvironmental@hotmail.com

Project Name:01- 00194 / Eastern Reg. High School - Liw
Initial**Customer PO:****EMSL Sales Rep:**

Josh Silverman

Received:

12/23/2024 09:00

Reported:

01/22/2025 16:36

Notes and Definitions

Item	Definition
P2	Sample was preserved at the lab prior to analysis.
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

SAMPLENAME	LABSAMPID	MATRIX	SAMPDATE	METHODCODE	ANALYTE	RESULT	RL	UNITS
LW 041	AD05572-01	Drinking Water	12/21/2024 7:32	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 042	AD05572-02	Drinking Water	12/21/2024 7:33	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 053	AD05572-03	Drinking Water	12/21/2024 7:35	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 053 A	AD05572-04	Drinking Water	12/21/2024 7:36	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 026	AD05572-05	Drinking Water	12/21/2024 7:37	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 35	AD05572-06	Drinking Water	12/21/2024 7:38	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 050	AD05572-07	Drinking Water	12/21/2024 7:39	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 050 A	AD05572-08	Drinking Water	12/21/2024 7:40	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 025	AD05572-09	Drinking Water	12/21/2024 7:41	01-Metals 200.8	Lead (Pb)	1.10	1.00	µg/L
LW 025 A	AD05572-10	Drinking Water	12/21/2024 7:42	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 025 B	AD05572-11	Drinking Water	12/21/2024 7:43	01-Metals 200.8	Lead (Pb)	18.9	1.00	µg/L
LW 029	AD05572-12	Drinking Water	12/21/2024 7:44	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 029 A	AD05572-13	Drinking Water	12/21/2024 7:45	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 030	AD05572-14	Drinking Water	12/21/2024 7:46	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 035	AD05572-15	Drinking Water	12/21/2024 7:47	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 035 A	AD05572-16	Drinking Water	12/21/2024 7:48	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 037	AD05572-17	Drinking Water	12/21/2024 7:49	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 037 A	AD05572-18	Drinking Water	12/21/2024 7:50	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 038	AD05572-19	Drinking Water	12/21/2024 7:51	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 019 A	AD05572-20	Drinking Water	12/21/2024 7:56	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 019 B	AD05572-21	Drinking Water	12/21/2024 7:57	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 018	AD05572-22	Drinking Water	12/21/2024 7:58	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 018 A	AD05572-23	Drinking Water	12/21/2024 8:00	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 018 C	AD05572-24	Drinking Water	12/21/2024 8:02	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 017 D	AD05572-25	Drinking Water	12/21/2024 8:03	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 017 C	AD05572-26	Drinking Water	12/21/2024 8:04	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 017	AD05572-27	Drinking Water	12/21/2024 8:05	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 017 A	AD05572-28	Drinking Water	12/21/2024 8:06	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 014 A	AD05572-29	Drinking Water	12/21/2024 8:07	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 014 B	AD05572-30	Drinking Water	12/21/2024 8:08	01-Metals 200.8	Lead (Pb)	12.6	1.00	µg/L
LW 012 D	AD05572-31	Drinking Water	12/21/2024 8:09	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 012 A	AD05572-32	Drinking Water	12/21/2024 8:10	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L
LW 012	AD05572-33	Drinking Water	12/21/2024 8:11	01-Metals 200.8	Lead (Pb)	ND	1.00	µg/L

LW 013B	AD05572-34	Drinking Water	12/21/2024 8:12	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 010 A	AD05572-35	Drinking Water	12/21/2024 8:13	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 010	AD05572-36	Drinking Water	12/21/2024 8:14	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 09B	AD05572-37	Drinking Water	12/21/2024 8:15	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 007	AD05572-38	Drinking Water	12/21/2024 8:16	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 007 A	AD05572-39	Drinking Water	12/21/2024 8:17	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 003 B	AD05572-40	Drinking Water	12/21/2024 8:18	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 003 C	AD05572-41	Drinking Water	12/21/2024 8:19	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 004 B	AD05572-42	Drinking Water	12/21/2024 8:20	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 031	AD05572-43	Drinking Water	12/21/2024 8:22	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 031 A	AD05572-44	Drinking Water	12/21/2024 8:23	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 052	AD05572-45	Drinking Water	12/21/2024 8:24	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 054	AD05572-46	Drinking Water	12/21/2024 8:25	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 03	AD05572-47	Drinking Water	12/21/2024 8:27	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 03 A	AD05572-48	Drinking Water	12/21/2024 8:28	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 06 A	AD05572-49	Drinking Water	12/21/2024 8:29	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 06 B	AD05572-50	Drinking Water	12/21/2024 8:30	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 005	AD05572-51	Drinking Water	12/21/2024 8:31	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 005 A	AD05572-52	Drinking Water	12/21/2024 8:32	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 005 B	AD05572-53	Drinking Water	12/21/2024 8:33	01-Metals 200.8 Lead (Pb)	Lead	3.54	1.00 µg/L
LW 049 A	AD05572-54	Drinking Water	12/21/2024 8:36	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 048	AD05572-55	Drinking Water	12/21/2024 8:37	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 048 A	AD05572-56	Drinking Water	12/21/2024 8:38	01-Metals 200.8 Lead (Pb)	Lead	2.54	1.00 µg/L
LW 048 B	AD05572-57	Drinking Water	12/21/2024 8:39	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 048 C	AD05572-58	Drinking Water	12/21/2024 8:40	01-Metals 200.8 Lead (Pb)	Lead	4.07	1.00 µg/L
LW 048 D	AD05572-59	Drinking Water	12/21/2024 8:41	01-Metals 200.8 Lead (Pb)	Lead	3.44	1.00 µg/L
LW 048 E	AD05572-60	Drinking Water	12/21/2024 8:42	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 048 F	AD05572-61	Drinking Water	12/21/2024 8:43	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 048 G	AD05572-62	Drinking Water	12/21/2024 8:44	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 048 H	AD05572-63	Drinking Water	12/21/2024 8:45	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 048 I	AD05572-64	Drinking Water	12/21/2024 8:46	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 048 J	AD05572-65	Drinking Water	12/21/2024 8:47	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 048 K	AD05572-66	Drinking Water	12/21/2024 8:48	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L
LW 048 L	AD05572-67	Drinking Water	12/21/2024 8:49	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00 µg/L

LW 048 M	AD05572-68	Drinking Water	12/21/2024 8:50	01-Metals 200.8	Lead (Pb)	Lead	ND	1.00 µg/L
LW 048 N	AD05572-69	Drinking Water	12/21/2024 8:51	01-Metals 200.8	Lead (Pb)	Lead	ND	1.00 µg/L
LW 048 O	AD05572-70	Drinking Water	12/21/2024 8:52	01-Metals 200.8	Lead (Pb)	Lead	ND	1.00 µg/L
LW 048 9	AD05572-71	Drinking Water	12/21/2024 8:53	01-Metals 200.8	Lead (Pb)	Lead	ND	1.00 µg/L
LW 040	AD05572-72	Drinking Water	12/21/2024 8:54	01-Metals 200.8	Lead (Pb)	Lead	ND	1.00 µg/L
LW 15A	AD05572-73	Drinking Water	12/21/2024 8:55	01-Metals 200.8	Lead (Pb)	Lead	ND	1.00 µg/L
LW 15	AD05572-74	Drinking Water	12/21/2024 8:56	01-Metals 200.8	Lead (Pb)	Lead	ND	1.00 µg/L
LW 016A	AD05572-75	Drinking Water	12/21/2024 8:57	01-Metals 200.8	Lead (Pb)	Lead	ND	1.00 µg/L
LW 024	AD05572-76	Drinking Water	12/21/2024 8:58	01-Metals 200.8	Lead (Pb)	Lead	ND	1.00 µg/L
Blank	AD05572-77	Drinking Water	12/21/2024	01-Metals 200.8	Lead (Pb)	Lead	ND	1.00 µg/L
LW-0120 A	AD05572-78	Drinking Water	12/21/2024 8:59	01-Metals 200.8	Lead (Pb)	Lead	ND	1.00 µg/L
LW-09 A	AD05572-79	Drinking Water	12/21/2024 9:00	01-Metals 200.8	Lead (Pb)	Lead	ND	1.00 µg/L
LW-09 C	AD05572-80	Drinking Water	12/21/2024 9:01	01-Metals 200.8	Lead (Pb)	Lead	ND	1.00 µg/L
LW-09 D	AD05572-81	Drinking Water	12/21/2024 9:02	01-Metals 200.8	Lead (Pb)	Lead	1.09	1.00 µg/L
LW-006	AD05572-82	Drinking Water	12/21/2024 9:03	01-Metals 200.8	Lead (Pb)	Lead	ND	1.00 µg/L
LW-00A	AD05572-83	Drinking Water	12/21/2024 9:04	01-Metals 200.8	Lead (Pb)	Lead	ND	1.00 µg/L
LW-00B	AD05572-84	Drinking Water	12/21/2024 9:05	01-Metals 200.8	Lead (Pb)	Lead	ND	1.00 µg/L
LW-052A	AD05572-85	Drinking Water	12/21/2024 9:06	01-Metals 200.8	Lead (Pb)	Lead	ND	1.00 µg/L
LW-907	AD05572-86	Drinking Water	12/21/2024 9:07	01-Metals 200.8	Lead (Pb)	Lead	2.58	1.00 µg/L



Chain of Custody

— Environmental Lead —

Contact Information

Client Company: Coastal Enviro
Office Address: PO Box 167
City, State, Zip: Hammoncton NJ
Fax Number: 6095616197 08037
Email Address: CoastalEnviro.com

Project Number: Eastern HS Low Conf-1
Project Name: _____
Primary Contact: C. Ledden
Office Phone: _____
Cell Phone: 6098209312

IATL is accredited by the National Lead Laboratory Accreditation Program (NLLAP) to perform analytical testing of environmental samples for lead (Pb). The accreditation is through AIAA-LAP, LLC and several other nationally recognized state programs.

Matrix/Method:

- ☐ Paint by AAS: ASTM D3335-85a, 2009
☐ Wipe/Dust by AAS: SW 846: 3050B: 700B, 2010
☐ Air by AAS: NIOSH 7082, 1994
☐ Soil by AAS: EPA SW 846 (Soil)
☒ Water by AAS-GF: ASTM D3559-03D, USEPA 40CFR 141.11B, 2010 (200.8)
☐ Other Metals (Cd, Zn, Cr) by AAS
☐ Toxicity Characteristic Leaching Procedure (TCLP) by AAS: USEPA 1311
☐ Other _____

Special Instructions:

— NON Compliant Conf Test
— Need Excel Form

Turnaround Time


Preliminary Results Requested Date: _____

- ☐ 10 Day ☐ 5 Day ☒ 3 Day ☐ 2 Day ☐ 1 Day* ☐ 12 Hour** ☐ 6 Hour** ☐ RUSH**
* End of next business day unless otherwise specified. ** Matrix Dependent. *** Please notify the lab before shipping***

Chain of Custody

Relinquished (Name/Organization): Cathy Ledden
Received (Name / IATL): _____
Sample Login (Name / IATL): _____
Analysis (Name(s) / IATL): _____
QA/QC Review (Name / IATL): _____
Archived / Released: _____

Date: 2/13/25 Time: _____
Date: _____ Time: _____
Date: _____ Time: FEB 13 2025
Date: _____ Time: _____
Date: _____ Time: _____
Date: _____ Time: _____
Date: _____ Time: _____



Client: Coastal Environmental Project: Eastern HS Lin CONF-1

[illegible]

* = Insufficient Sample Provided to Perform QC Reanalysis (<200mg)
 ** = Insufficient Sample Provided to Analyze (<50mg) *** = Matrix/Substrate Interference Possible
 #B = Method Requires the Submission of Blank(s) ML = Multi Layered Sample, May result in Inconsistent results,
 These preliminary results are issued by iATL to expedite procedures by clients based upon the above data. iATL assumes that all of the sampling methods
 and data upon which these results are based, has been accurately supplied by the client. These results may not have been reviewed by the Laboratory Director.
 Final Certificate of Analysis will follow these preliminary results. The signed COA is to be considered the official results. All BPA, HWP, and NDEP
 conditions apply.

Calculating 25 years...one sample at a time
was w. her son

of
LATI
P. 43



Built Environment Testing

IATL

9000 Commerce Parkway Suite B
Mt. Laurel, New Jersey 08054
Telephone: 856-231-9449
Email: customerservice@iatl.com

CERTIFICATE OF ANALYSIS

Client: Coastal Environmental
721 Flittertown Rd
Hammonton NJ 08037

Report Date: 2/19/2025
Report No.: 709762 - Lead Water
Project: Eastern HS LIW Conf-1
Project No.:

Client: COA212

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.: 7821486
Client No.: LW-025B-C

Location: 500 Kitchen Pot Filler
* Sample acidified to pH <2.

Result(ppb): 1.50

Lab No.: 7821487
Client No.: Blank

Location:
* Sample acidified to pH <2.

Result(ppb): <1.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 2/13/2025

Date Analyzed: 02/19/2025

Signature:

Analyst: Chad Shaffer

Approved By:

Frank E. Ehrenfeld, III
Laboratory Director



Built Environment Testing
iATL

9000 Commerce Parkway Suite B
Mt. Laurel, New Jersey 08054
Telephone: 856-231-9449
Email: customerservice@iatl.com

CERTIFICATE OF ANALYSIS

Client: Coastal Environmental
721 Flittertown Rd
Hammonton NJ 08037

Client: COA212

Report Date: 2/19/2025
Report No.: 709762 - Lead Water
Project: Eastern HS LIW Conf-1
Project No.:

Appendix to Analytical Report:

Customer Contact: Cathy Ledden
Analysis: AAS-GF - ASTM D3559-15D

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com
iATL Office Manager: wchampion@iatl.com
iATL Account Representative: Shirley Clark
Sample Login Notes: See Batch Sheet Attached
Sample Matrix: Water
Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-15D

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

Note: These methods are analytically equivalent to iATL's accredited method;

- USEPA 40CFR 141.11B
- USEPA 200.9 Pb, AAS-GF, RL <2 ppb/sample
- USEPA SW 846-7421 - Pb(AAS-GF, RL <2 ppb/sample)

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 1.0 PPB



Built Environment Testing
iATL

9000 Commerce Parkway Suite B
Mt. Laurel, New Jersey 08054
Telephone: 856-231-9449
Email: customerservice@iatl.com

CERTIFICATE OF ANALYSIS

Client: Coastal Environmental
721 Flittertown Rd
Hammonton NJ 08037

Client: COA212

Report Date: 2/19/2025
Report No.: 709762 - Lead Water
Project: Eastern HS LIW Conf-1
Project No.:

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Matrix spiking is performed on each client batch to determine if interferences could impact results. When spike recoveries fall out of acceptable range matrix interference is suspected and samples are diluted until acceptable spike recovery can be achieved. Reporting limits will increase by the same degree as the dilution required.

Note: Sample dilution required due to matrix interference.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

* ASTM D3559 (D) calls for the addition of acid at the time of sampling. Unless so noted on the chain of custody by the client iATL acidifies samples to a pH of <2 at least 24 hours prior to analysis.

CERTIFICATE OF ANALYSIS

Client: Coastal Environmental
721 Flittertown Rd
Hammonton NJ 08037

Report Date: 4/8/2025
Report No.: 711719 - Lead Water
Project: Eastern HS-Initial Concession Stand LIW
Project No.:

Client: COA212

Appendix to Analytical Report:

Customer Contact: Cathy Ledden
Analysis: AAS-GF - ASTM D3559-15D

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com
iATL Office Manager: wchampion@iatl.com
iATL Account Representative: Shirley Clark
Sample Login Notes: See Batch Sheet Attached
Sample Matrix: Water
Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-15D

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

Note: These methods are analytically equivalent to iATL's accredited method;

- USEPA 40CFR 141.11B
- USEPA 200.9 Pb, AAS-GF, RL <2 ppb/sample
- USEPA SW 846-7421 - Pb(AAS-GF, RL <2 ppb/sample)

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 1.0 PPB



Built Environment Testing

iATL

9000 Commerce Parkway Suite B
Mt. Laurel, New Jersey 08054
Telephone: 856-231-9449
Email: customerservice@iatl.com

CERTIFICATE OF ANALYSIS

Client: Coastal Environmental
721 Flittertown Rd
Hammonton NJ 08037

Report Date: 4/8/2025
Report No.: 711719 - Lead Water
Project: Eastern HS-Initial Concession Stand LIW
Project No.:

Client: COA212

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Matrix spiking is performed on each client batch to determine if interferences could impact results. When spike recoveries fall out of acceptable range matrix interference is suspected and samples are diluted until acceptable spike recovery can be achieved. Reporting limits will increase by the same degree as the dilution required.

Note: Sample dilution required due to matrix interference.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

* ASTM D3559 (D) calls for the addition of acid at the time of sampling. Unless so noted on the chain of custody by the client iATL acidifies samples to a pH of <2 at least 24 hours prior to analysis.



004014704

Chain of Custody

- Environmental Lead -

Contact Information

Client Company: Coastal Environmental Project Number: Eastern HS - Initial
Office Address: PO Box 167 Project Name: Concession Stand LNW
City, State, Zip: Hammoncton NJ 08037 Primary Contact: C. L. L.
Fax Number: 609 561 6197 Office Phone: 609 820 9312
Email Address: CoastalEnvironmental@Hotmail.com Cell Phone: 11 11

iATL is accredited by the National Lead Laboratory Accreditation Program (NLLAP) to perform analytical testing of environmental samples for lead (Pb). The accreditation is through AIHA-LAP, LLC and several other nationally recognized state programs.

Matrix/Method:

- ☐ Paint by AAS: ASTM D3335-85a, 2009
☐ Wipe/Dust by AAS: SW 846: 3050B: 700B, 2010
☐ Air by AAS: NIOSH 7082, 1994
☐ Soil by AAS: EPA SW 846 (Soil)
☒ Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 - Unpreserved
☐ Other Metals (Cd, Zn, Cr) by AAS
☐ Toxicity Characteristic Leaching Procedure (TCLP) by AAS: US EPA 1311
☐ Other

Special Instructions:

Now Regulated
- Need Excel Sh.

Turnaround Time

Preliminary Results Requested Date:

Specific date / time

☐ Verbal ☒ Email ☐ Fax

☐ 10 Day ☐ 5 Day ☒ 3 Day ☐ 2 Day ☐ 1 Day* ☐ 12 Hour** ☐ 6 Hour** ☐ RUSH**

* End of next business day unless otherwise specified. ** Matrix Dependent. *** Please notify the lab before shipping***

Chain of Custody

Relinquished (Name/Organization): Coastal Date: 4/13/2005 Time: 10:00 AM
Received (Name / iATL): _____ Date: _____ Time: _____
Sample Login (Name / iATL): _____ Date: _____ Time: _____
Analysis (Name(s) / iATL): _____ Date: _____ Time: _____
QA/QC Review (Name / iATL): _____ Date: _____ Time: _____
Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

Sample Log

—Environmental Lead—

Client: Coastal Environmental Project: Eastern HS - Initial

Sampling Date/Time: 4/3/25 Concession Stand Line

Client Sample #	IATL #	Location/ Description	Flow Rate	Start End	Sampling time (min)	Area (ft ²) Volume (L)	Results ()
LW 049	7833602	Concession Ice maker					
LW 049B	7833603	Concession Sink					
Blank	7833604						

* = Insufficient Sample Provided to Perform QC Reanalysis (<200mg)

** = Insufficient Sample Provided to Analyze (<50mg) *** = Matrix / Substrate Interference Possible

FB = Method Requires the submittal of blank(s). ML = Multi Layered Sample. May result in inconsistent results.

These preliminary results are issued by IATL to expedite procedures by clients based upon the above data. IATL assumes that all of the sampling methods and data upon which these results are based, has been accurately supplied by the client. These results may not have been reviewed by the Laboratory Director. Final Certificate of Analysis will follow these preliminary results. The signed COA is to be considered the official results. All EPA, HUD, and NDEP conditions apply.



Built Environment Testing
iATL

9000 Commerce Parkway Suite B
Mt. Laurel, New Jersey 08054
Telephone: 856-231-9449
Email: customerservice@iatl.com

CERTIFICATE OF ANALYSIS

Client: Coastal Environmental
721 Flittertown Rd
Hammonton NJ 08037

Report Date: 4/8/2025
Report No.: 711719 - Lead Water
Project: Eastern HS-Initial Concession Stand LIW
Project No.:

Client: COA212

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:7833602
Client No.:LW049

Location:Concession Ice Maker
* Sample acidified to pH <2.

Result(ppb):<1.00

Lab No.:7833603
Client No.:LW049B

Location:Concession Sink
* Sample acidified to pH <2.

Result(ppb):<1.00

Lab No.:7833604
Client No.:Blank

Location:
* Sample acidified to pH <2.

Result(ppb):<1.00

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 4/3/2025

Date Analyzed: 04/08/2025

Signature:

Analyst: Chad Shaffer

Approved By:

Frank E. Ehrenfeld, III
Laboratory Director

Dated : 4/8/2025 2:10:33